



Nepal Rastra Bank,  
Assets and Service Management Department  
Baluwatar, Kathmandu  
**Addendum Notice No. 1/Admin**  
**Date: 2081-04-18**

This is to notify all eligible bidders that Nepal Rastra Bank, Baluwatar, Kathmandu, Nepal, has made the following amendments to the Bidding Documents for the **Supply, Delivery and Installation of Air Conditioners 26 Sets (IFB No.: NRB/GOODS/NCB/04/080/81)** as per the notice published on **2081-03-28** in "Gorkhapatra" national daily newspaper.

<b>Specification of 1.5 Ton Air Conditioner</b>			
<b>S.N.</b>	<b>Particulars</b>	<b>Current Provisions</b>	<b>Amendments</b>
1.	Section V- Schedule of Requirements Pg. 55 (Technical Specifications- S.N. 8. Copper Piping Length)	10 m (average)	6m (average)
2.	Section V- Schedule of Requirements Pg. 55 (Technical Specifications- S.N. 12. Cable)	Approx. 20m of 4 mm <sup>2</sup> copper cable for each Air Conditioner <b>(to be supplied by the contractor)</b>	Approx. 12m of 4 mm <sup>2</sup> copper cable for each Air Conditioner <b>(to be supplied by the contractor)</b>

<b>Specification of 2 Ton Air Conditioner</b>			
<b>S.N.</b>	<b>Particulars</b>	<b>Current Provisions</b>	<b>Amendments</b>
1.	Section V- Schedule of Requirements Pg. 56 (Technical Specifications- S.N. 8. Copper Piping Length)	10 m (average)	8m (average)
2.	Section V- Schedule of Requirements Pg. 56 (Technical Specifications- S.N. 12. Cable)	Approx. 20 m of 4 mm <sup>2</sup> copper cable for each Air Conditioner <b>(to be supplied by the contractor)</b>	Approx. 20m of 4 mm <sup>2</sup> copper cable for each Air Conditioner <b>(to be supplied by the contractor)</b>